

► TSD-IG | MECHANICAL DETAILS & DRAWINGS (2 HEATER)

TSD-IG | 2-Heater Mechanical Information Table

MODEL	Air Curtain Width - A (in.)	Mounting Width - B (in.)	Hanging Width - C (in.)	Flue Diameter - D (in.)	Heater Size	Gas Inlet (in.)
TSD-2-120IG	123.13	119.13	30.63	5	2 × 250	0.75
TSD-2-132IG	135.13	131.13	30.63	5	2 × 250	0.75
TSD-2-144IG	147.13	143.13	30.63	5	2 × 250	0.75
TSD-3-144IG	147.25	143.25	30.63	5	2 × 250	0.75
TSD-3-156IG	159.25	155.25	48.63	6	2 × 350	0.75
TSD-3-168IG	171.25	167.25	48.63	6	2 × 350	0.75
TSD-3-180IG	183.25	179.25	48.63	6	2 × 350	0.75
TSD-3-192IG	195.25	191.25	48.63	6	2 × 350	0.75
TSD-4-192IG	195.38	191.38	48.63	6	2 × 400	0.75
TSD-3-204IG	207.25	203.25	48.63	6	2 × 400	0.75
TSD-4-204IG	207.38	203.38	48.63	6	2 × 400	0.75
TSD-3-216IG	219.25	215.25	48.63	6	2 × 400	0.75
TSD-4-216IG	219.38	215.38	48.63	6	2 × 400	0.75



NOTES

1. Verify that overall dimensions will fit in the opening.
2. Adequacy of support structure to be verified by a professional structural engineer.
3. Air curtain to be installed so that the air stream is unobstructed.

